














17. The Licencee shall:
- a) take one composite sample of effluent from the sewage treatment plant during the discharge period once each month;
  - b) have the composite effluent sample analyzed at an accredited laboratory for five day biochemical oxygen demand, total suspended solids and total phosphorus content, using methods from the Standard Methods for the Examination of Water and Wastewater, or using other methods approved by the Director;
  - c) have the grab samples analyzed at an accredited laboratory for fecal coliform content and total coliform content using methods from the Standard Methods for the Examination of Water and Wastewater, or using other methods approved by the Director, and
  - d) report the results to the Director within 60 days of the samples being taken.
18. The Licencee shall actively participate in any future watershed based management study, plan or nutrient reduction program, approved by the Director, for the Winnipeg River and associated waterways and watersheds.
19. The Licencee shall meet a phosphorus limit of 1 mg/L by December 31, 2010.

**REVIEW AND REVOCATION**

- A. If, in the opinion of the Director the Licencee is exceeding or is exceeding or has or is failing to meet the specifications, limits, terms, or conditions set out in this Licence, the Director may, temporarily or permanently, revoke this Licence.
- B. If, in the opinion of the Director new evidence warrants a change in the specifications, limits, terms or conditions of this Licence, the Director may require the filing of a new proposal pursuant to Section 11 of The Environment Act.

  
\_\_\_\_\_  
Tracey Braun, M.Sc.  
Director  
Environment Act