

Environment Act Licence

Manitoba
Environment and
Workplace Safety
and Health



Licence No. 1201 E

Issue Date DECEMBER 5, 1988


In accordance with the Manitoba Environment Act (C.C.S.M. c. E125)

THIS LICENCE IS ISSUED TO:

MANITOBA HYDRO; APPLICANT

The following terms and conditions shall be complied with in connection with the construction and operation of a 115 KV transformer station to service Sherridon, Manitoba:

1. The Applicant shall construct and operate the 115 KV transformer station in accordance with The Transmission and Stations Engineering and Construction Report No. 88-D1, dated March, 1988, and as prepared by B. Manning.
2. The Applicant shall investigate the feasibility of constructing on-site containment pits as a precautionary measure to prevent environmental impacts in the event of spill or leak of insulating oil. A report on the feasibility investigation shall be submitted to the Director on or before January 1, 1989.
3. The Applicant shall enclose the transformer station site with a six foot high fence and install Danger Warning signs in both English and Cree along the fence at this location.
4. This Licence replaces Licence No. 1201 which is hereby rescinded.



C. B. Orcutt
Director
Environmental Control Services

File: 2915.00