

Environment Act Licence

Manitoba
Environment and
Workplace Safety
and Health



Licence No. 1228

Issue Date September 29, 1988

In accordance with the Manitoba Environment Act (C.C.S.M. c. E125)

THIS LICENCE IS ISSUED TO:

BREEZY BEND COUNTRY CLUB; APPLICANT

The following limits, terms and conditions shall be complied with in connection with the operation of a sewage treatment plant located on Pt. R.L. 7 in the Parish of Headingly serving the Breezy Bend Golf and Country Club and with the discharge of treated effluent via closed conduit to the Assiniboine River:

1. The applicant shall not discharge effluent from the sewage treatment plant where:
 - (a) the organic content of the sewage effluent, as indicated by the five day biochemical oxygen demand, is in excess of 30 milligrams per litre;
 - (b) the fecal coliform content of the sewage effluent, as indicated by the M.P.N. Index is in excess of 200 per 100 millilitres of sample;
 - (c) the total coliform content of the sewage effluent, as indicated by the M.P.N. Index, is in excess of 1500 per 100 millilitres of sample;

as sampled at the overflow from the chlorine contact chamber.

2. The applicant shall monitor the chlorination process of the sewage treatment plant using the D.P.D. method or equivalent and shall record the results in a manner satisfactory to the Director.
3. The applicant shall dispose of waste solids and sewage sludge in a manner satisfactory to the Director.

4. The applicant shall, in case of physical or mechanical breakdown of the wastewater collection or treatment system:
- (a) notify the Director immediately;
 - (b) identify the repairs required to the wastewater collection or treatment system;
 - (c) complete the repairs in accordance with the written instructions of the Director.



C.B. Orcutt
Director
Environmental Control Services

FILE NO: 2943.0