Environment Act Licence Manitoba Environment



Licence No. \_\_\_\_\_2105 Issue Date September 5, 1995

In accordance with the Manitoba Environment Act (C.C.S.M. c. E125)

## THIS LICENCE IS ISSUED TO:

## THE RURAL MUNICIPALITY OF SPRINGFIELD; "the Licencee"

for the construction and operation of the Development being a municipal water supply system consisting of two wells located on a municipal road allowance adjacent to NE 30-11-5E, and reservoirs, pumphouses and distribution systems in the communities of Oakbank and Dugald as well as connecting pipelines, subject to the following specifications, limits, terms and conditions:

## SPECIFICATIONS, LIMITS, TERMS AND CONDITIONS

- 1. The Licencee shall construct the Development in accordance with The Environment Act Proposal dated August 25, 1994, and additional information contained in a letter from I. D. Engineering Canada Inc. to Manitoba Environment dated December 7, 1994, except as otherwise required by this Licence.
- 2. The Licencee shall, prior to the commencement of construction activities, submit final plans of all components of the Development for the approval of the Director.
- 3. The Licencee shall notify the Director of Manitoba Environment's Winnipeg Region not less than two weeks prior to beginning construction of the Development.
- 4. The Licencee shall, prior to undertaking construction on or adjacent to highway rights-of-way, obtain all necessary permits and agreements from Manitoba Highways and Transportation and the Highway Traffic Board.
- 5. The Licencee shall stabilize and re-vegetate any areas of soil disturbed by the construction of the Development.
- 6. The Licencee shall ensure that the combined rate of water withdrawal from the wells of the Development does not exceed the quantity specified in a Water Rights Licence issued for the Development by the Water Resources Branch of Manitoba Natural Resources. The rate of water withdrawal may be changed as authorized by the Water Rights Licence and future renewal licences.
- 7. The Licencee shall monitor the effects of the Development as described in a letter from the Water Resources Branch to the Licencee dated May 26, 1995. Records of the monitoring shall be submitted to the Director annually, and a summary report on the monitoring shall be submitted to the Director following the tenth year of operation of the Development.

The Rural Municipality of Springfield Licence No. 2105 Page 2 of 2

- 8. The Licencee shall maintain records of daily withdrawals from each well in the water supply system, and daily water use in Oakbank and Dugald. These records shall be made available to Manitoba Environment and Manitoba Natural Resources on request. Monthly summaries of these records shall be submitted annually to Manitoba Environment and Manitoba Natural Resources.
- 9. The Licencee shall ensure that approved backflow prevention devices are installed where necessary to prevent cross-connections between the Development and existing private water supply systems.
- 10. The Licencee shall ensure that private water supply wells which may be abandoned as a result of the Development are sealed by a licensed well driller in accordance with the requirements and recommendations of the Groundwater Management Section of the Manitoba Water Resources Branch.
- 11. The Licencee shall ensure that the operation of the municipal water supply is in accordance with Manitoba Regulations under The Public Health Act and all operating requirements as recommended by Manitoba Environment.
- 12. The Licencee shall ensure that all used oil products and other regulated hazardous wastes generated by the machinery used in the construction and operation of the Development are collected and disposed of in accordance with all applicable Manitoba Environment and legislation requirements.
- 13. The Licencee shall ensure that fuel storage areas established for the construction and operation of the Development shall comply with the requirements of Manitoba Regulation 97/88R respecting Storage and Handling of Gasoline and Associated Products.

## **REVOCATION**

If, in the opinion of the Director, the Licencee has exceeded or is exceeding the limits, or has not complied or is not complying with the specifications, terms or conditions set out herein, the Director may revoke this Licence either temporarily or permanently.  $\wedge$ 

Serge Director Environment/Act

File No: 3876.00