

Environment Act Licence Loi sur l'environnement Licence

Manitoba
Conservation
Conservation
Manitoba



Licence No./Licence n° 2435 RR

Issue Date/Date de délivrance December 23, 1999

Revised: December 30, 1999
July 12, 2002

**IN ACCORDANCE WITH THE MANITOBA ENVIRONMENT ACT (C.C.S.M. c. E125)
THIS LICENCE IS ISSUED PURSUANT TO SECTIONS 11(1) AND 14(2) TO:**

**THE RURAL MUNICIPALITY OF HEADINGLEY AND
THE PROVINCE OF MANITOBA REPRESENTED BY THE MINISTER
OF TRANSPORTATION AND GOVERNMENT SERVICES; "the Licences"**

for the construction and operation of the Development being a modified Sequencing Batch Reactor wastewater treatment plant located on lot No. 36 and 32, Parish of Headingley and on Lot No. 227, Parish of St. Francois Xavier located within the Rural Municipality of Headingley, and in accordance with the Notice of Alteration filed by The Manitoba Water Services Board under Section 14 of The Environment Act on March 4, 1999, the Notice of Alteration dated March 28, 2002 and the additional information dated June 17, 2002 and July 11, 2002 and subject to the following specifications, limits, terms and conditions:

DEFINITIONS

In this Licence,

"**accredited laboratory**" means an analytical facility accredited by the Standard Council of Canada (SCC), or accredited by another accrediting agency recognized by Manitoba Conservation to be equivalent to the SCC, or be able to demonstrate, upon request, that it has the quality assurance/quality control (QA/QC) procedures in place equivalent to accreditation based on the international standard ISO/IEC 17025, or otherwise approved by the Director;

"**affected area**" means a geographical area excluding the property of the development;

"**approved**" means approved by the Director in writing;

"**as constructed drawings**" means engineering drawings complete with all dimensions which indicate all features of the Development as it has actually been built;

"**bioassay**" means a method of determining toxic effects of industrial wastes and other wastewaters by using viable organisms;

"**composite sample**" means a quantity of wastewater consisting of a minimum of 10 equal volumes of effluent, or flow proportional volumes collected over a 24-hour period, and may be collected manually or by means of an automatic sampling device;

"**Director**" means an employee so designated pursuant to The Environment Act;

**** A COPY OF THIS LICENCE MUST BE KEPT ON SITE AT THE DEVELOPMENT AT ALL TIMES ****

