

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION  
UNDER THE CLEAN ENVIRONMENT ACT

---

275  
m.j.

Re: The Clean Environment Commission and Marble Ridge Colony, applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, the Marble Ridge Colony has submitted an application to the Clean Environment Commission to prescribe limits in connection with the operation of a sewage lagoon system to service the Marble Ridge Colony, said lagoon being located in Section 22-25-1W in the Local Government District of Fisher, with effluent discharge into the surrounding lands which are under the lawful control of the applicant and which drain into the Fisher River,

AND WHEREAS no representation was made to the Clean Environment Commission by any person who is or is likely to be affected by an order of the Commission prescribing limits in connection with the said operation,

AND WHEREAS the Clean Environment Commission considered the application on the 14th day of May 1973,

IT IS HEREBY ORDERED THAT


1. The applicant shall ensure that all facilities for the treatment of sewage and holding of effluent are constructed of impervious materials and said facilities are maintained and operated in such a manner as to prevent the contamination of groundwater,
2. The applicant shall ensure that said sewage lagoon system is operated in such a manner as to minimize the release of offensive odours,
3. The applicant shall ensure that the biochemical oxygen demand loading on the primary cell of said sewage lagoon system does not exceed 50 pounds per acre per day,
4. The applicant shall ensure that the quality of the final effluent from said sewage lagoon system is such that:
  - (1) the biochemical oxygen demand does not exceed 30 milligrams per litre and
  - (2) the total coliform MPN index does not exceed 1500 per 100 millilitres of sample,

*Assigned to  
Eng. Dept.  
June 6/73*

5. The applicant shall ensure that no discharge of effluent from said holding pond takes place between the first day of November in any year and the fifteenth day of May in the following year, and between the fifteenth day of June and the fifteenth day of September in any one year.
6. The applicant shall ensure that the secondary cell of the lagoon is chlorinated by a dose equivalent to five milligrams per litre of chlorine 24 hours prior to discharge.

Order No. 275

Dated at the City of Winnipeg  
this 25th day of May .1973



Chairman,  
Clean Environment Commission

C-b-664

cc: Regional Services  
Aug 17/73