

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
UNDER THE CLEAN ENVIRONMENT ACT

RE: The Clean Environment Commission and Imperial Oil Limited, applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, Imperial Oil Limited, 379 Broadway Avenue, Winnipeg, submitted an application to The Clean Environment Commission in connection with the operation of a sewage treatment system located in the SW $\frac{1}{4}$ of Section 35-14-18 WPM to serve 4 & 10 Esso restaurant and service station located on the NE corner at the junction of Provincial Highway 4 and 10 in the Rural Municipality of Odanah, Manitoba,

AND WHEREAS no representation was made to The Commission by any person who is, or is likely to be, affected by an Order of The Commission prescribing limits in connection with the said operation,

AND WHEREAS The Clean Environment Commission considered the application on the 15th day of October, 1974,

IT IS HEREBY ORDERED THAT

1. The applicant shall ensure that the said sewage treatment system is constructed, maintained and operated in such a manner as to prevent the contamination of groundwater,
2. The applicant shall ensure that the said sewage treatment system is operated in such a manner as to minimize the release of offensive odours,
3. The applicant shall ensure that the organic loading (in terms of five day biochemical oxygen demand) on the said sewage treatment system does not exceed 25 pounds per day,
4. The applicant shall ensure that no discharge of effluent from the said sewage treatment system takes place between the first day of November in any year and the fifteenth day of May of the following year,


*Assigned to
Water Pollution - EGK
CBO/BK
Oct 29/74*

5. The applicant shall ensure that the quality of the effluent from the said sewage treatment system, before discharge is such that:
 - (a) the biochemical oxygen demand (B.O.D.) does not exceed 30 milligrams per litre, and
 - (b) the total coliform content, as indicated by the MPN index, does not exceed 1500 per 100 millilitres of sample, and
 - (c) the non-filterable residue (suspended solids content) does not exceed 30 milligrams per litre,
6. The applicant shall ensure that the said sewage treatment system is fenced and locked to prevent unauthorized entrance.

Order No. 397

Dated at the City of Winnipeg.

this 22nd day of OCTOBER, 1974.



Chairman
Clean Environment Commission

C-b-247.1