

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION

UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and the VILLAGE OF STE. ANNE, Applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, the Manitoba Water Services Board submitted a proposal to the Department of Mines, Resources and Environmental Management in connection with the operation of a proposed sewage lagoon system to be located at River Lots 22 and 23 of Plan No. 16-1-1270 in the Rural Municipality of Ste. Anne, serving the Village of Ste. Anne;

AND WHEREAS in the absence of limits being prescribed by a Regulation under the said Act, the proposal was referred to The Clean Environment Commission for the prescribing of limits;

AND WHEREAS no representation was made by any person who is, or who is likely to be, affected by an Order of the Commission prescribing limits in connection with the said operation;

AND WHEREAS the said Commission considered the proposal on the 12th day of July, 1977;

IT IS HEREBY ORDERED THAT

1. The Applicant shall ensure that on and after the 1st day of November, 1978, the said proposed sewage lagoon is constructed, maintained and operated in such a manner as to:
  - (a) prevent the contamination of groundwater;
  - (b) minimize the release of offensive odours;
  - (c) ensure that the organic loading on the primary cell of the said system, in terms of five day biochemical oxygen demand, does not exceed 50 pounds per acre per day;
  - (d) ensure that no discharge of effluent takes place between the 1st day of November of any year and the 15th day of May of the following year without written permission from the Environmental Management Division of the Department of Mines, Resources and Environmental Management;
  - (e) ensure that the quality of the effluent is such that:

*assigned to WPC  
CSD/ci  
110728*

1. (e) (i) the five day biochemical oxygen demand does not exceed 30 milligrams per litre;  
  
(ii) the total coliform content as indicated by the MPN Index does not exceed 1500 per 100 millilitres of sample.
  
2. During the interim period, prior to completion of the proposed sewage lagoon system, the Applicant shall ensure that the existing sewage facility located on River Lot 52, immediately East of the Seine River, in the Village of Ste. Anne and the Rural Municipality of Ste. Anne is maintained and operated in such a manner as to:
  - (a) minimize the release of offensive odours;
  - (b) ensure that no discharge of effluent takes place between the 1st day of November of any year and the 15th day of May of the following year without written permission from the Environmental Management Division of the Department of Mines, Resources and Environmental Management;
  - (c) ensure that the quality of the effluent from the said existing sewage treatment lagoon is such that the total coliform content as indicated by the MPN Index does not exceed 1500 per 100 millilitres of sample.

Order No. 739

Dated at the City of Winnipeg

this 27th day of JULY, 1977.

  
Chairman,  
The Clean Environment Commission.

C-b- 112.1

Copies of the Order were sent to the following:

Mr. D. D. Blevins,  
Departmental Solicitor,  
Department of the Attorney-General,  
405 Broadway Avenue,  
Woodworth Building,  
WINNIPEG, Manitoba.

Mr. Lee Sage,  
Room 29,  
Legislative Building.

Mr. F. N. Steele,  
City of Winnipeg,  
Law Department,  
Civic Centre,  
510 Main Street,  
WINNIPEG, Manitoba.  
R3B 1B9

Provincial Library,  
200 Vaughan Street,  
WINNIPEG, Manitoba.

Margaret Allan,  
CBC TV,  
Box 160,  
WINNIPEG, Manitoba.

Mr. A. G. McLeod,  
Director,  
Environmental Control Branch.

Mr. Arthur J. Fiola  
Secretary Treasurer  
Village of Ste. Anne  
STE. ANNE, Manitoba  
ROA 1R0

Mr. R. M. Stokes  
General Manager  
Manitoba Water Services Board  
1445 Pembina Highway  
Winnipeg, Manitoba  
R3T 2C4

Mr. J. B. Goossen  
Secretary Treasurer  
Rural Municipality of  
Ste. Anne  
Ste. Anne, Manitoba.  
ROA 1R0