



Conservation and Water Stewardship

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg, Manitoba R3C 1A5
T 204 945-8321 F 204 945-5229
www.gov.mb.ca/conservation/eal

File: 3087.10

September 9, 2015

Mr. Walter Gross
Whiteshell Colony
General Delivery
River Hills, MB R0E 1T0

Dear Mr. Gross:

Re: Whiteshell Colony Wastewater Treatment Lagoon – Environment Act Licence No. 1377 R – Phosphorus Sampling and Monitoring Plan

Receipt of the July 24, 2015 Whiteshell Colony Lagoon Phosphorus Sampling and Monitoring Plan submitted by WSP on behalf of the Whiteshell Colony is acknowledged in accordance with Clause 42 of Environment Act Licence No. 1377 R.

The submission proposes an initial three year phosphorus sampling and monitoring program conducted during the spring and fall discharge campaigns. An additional two years of sampling and monitoring are proposed should the results on the three year program consistently exceed the 1mg/L total phosphorus limit.

The proposed phosphorus sampling and monitoring plan is approved in accordance with Clause 42 of Environment Act Licence No. 1377 R. Results from the sampling and monitoring plan should be recorded in the attached Nutrient Reduction Strategy Monitoring Plan spreadsheet and submitted as part of the annual report.

If you have any questions, please contact Jennifer Winsor, P.Eng. at 204-945-7012.

Yours sincerely,

“original signed by”
Tracey Braun, M.Sc.
Director

- c. Don Labossiere, Director – Environmental Compliance and Enforcement Branch,
Manitoba Conservation and Water Stewardship
Donna Smiley, Provincial Manager - Environmental Compliance and Enforcement
Branch, Manitoba Conservation and Water Stewardship
Diane Oertel, Regional Supervisor - Environmental Compliance and Enforcement
Branch, Manitoba Conservation and Water Stewardship
Jason Bunn – WSP (Jason.Bunn@wspgroup.com)
Public Registries