

## **Conservation and Water Stewardship**

Environmental Stewardship Division Environmental Approvals Branch 123 Main Street, Suite 160, Winnipeg Manitoba R3C 1A5 T 204 945-8321 F 204-945-5229 www.gov.mb.ca/conservation/eal

Client File No. 77.10

January 8, 2016

Brad D. Collett, BComm (Hons), MAcc, CPA, CA Chief Administrative Officer City of Dauphin 100 Main Street S Dauphin, MB R7N 1K3 Email: info@Dauphin.ca

Dear Mr. Collett:

## Re: Dauphin wastewater treatment lagoon - wastewater effluent limit for phosphorus in effect January 1, 2016

As you have been previously notified, your wastewater treatment lagoon at Dauphin is required to meet the 1 mg/L phosphorus limit as of January 1, 2016 in accordance with the Water Quality Standards, Objectives and Guidelines Regulation under *The Water Protection Act*. Your phosphorus compliance plan was approved July 16, 2013.

Your wastewater treatment lagoon for Dauphin operates under Environment Act Licence 413 VC. In addition to meeting the 1 mg/L phosphorus limit, you are hereby required to sample, analyze and report on the total phosphorus content of your wastewater effluent prior to discharging to surface water.

Should you have questions, please call Siobhan Burland Ross at 204-945-7015.

Yours sincerely,

"original signed by"

Tracey Braun, M.Sc. Director

c: Don Labossiere/Tim Prawdzik, Environmental Compliance and Enforcement Branch Nicole Armstrong, Director, Water Science and Management Branch Siobhan Burland Ross, Environmental Approvals Branch Public Registries